

(A)

(B)

NOTE:- Contractor is to provide a weathered builders kerb. Kerb to be a minimum of 50mm wide and 150mm above the finished roof surface. The kerb should be flat and level to +/- 3mm and be constructed in such a way as to provide a solid fixing platform. Should insulation be installed to the external side of the new kerb it is important that the insulation does not cause a back fall on the rooflight flashing detail (check with roof designer). If an existing kerb has been raised there may be a requirement for remedial works and internal decorations. All by others

Drawing No. XGlaze-Inst-001 Rev 2-11.04.19