

DECLARATION OF PERFORMANCE (Ref: 0086-CPR-755341)

20



Automatic opening smoke and heat ventilator XT-140-Ax-CE



Intended use for smoke and heat exhaust ventilation on flat and / or inclined roofs

Unique identification as per order number.

Velux Commercial Xtralite Limited, Spencer Road, Blyth Riverside Business Park, Blyth, NE24 5TG

Essential Characteristic	Performance	AVCP	hEN
Aerodynamic free area	Cv=0.40 (Annex B, B1)	System 1	EN 12101-2:2003
Reliability	Re 1000		
Snow load	SL 600		
Low ambient temperature	T (-15)		
Wind Load	WL 1500		
Resistance to heat	B 300		
Reaction to fire	F		

Notified body: BSI - 0086

The performance of the products identified with the above identification codes are in conformity with the relevant declared performances.

Factory production control requirements are assessed by the Notified Body. There are no dangerous substances in the product.

This declaration of performance is issued under the sole responsibility of the manufacturer Xtralite (Rooflights) Ltd.

Signed for and on behalf of the manufacturer by:

Name and position: Steven Steele Technical Services Manager	Place & date of issue: Blyth, Northumberland, UK Date: 03/10/2020	Signature:
---	---	----------------